

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 545a

EUROBOND LAMINATES LIMITED

| Product Name | Thickness (mm) | Fire resistance Integrity (min) | Fire resistance Insulation (min) | Maximum unsupported span (m) | Grade | Core Material | LPCB Ref. No |
|--------------|----------------|---------------------------------|----------------------------------|------------------------------|-------|---------------|--------------|
| Europanel | 86 | 60 | 60 | 3.0 | FR60 | Mineral fibre | 545a/05 |
| Extra | 113 | 30 | 30 | 7.5 | FR30 | Mineral fibre | |
| (wall panel) | 113 | 60 | 60 | 6.0 | FR60 | Mineral fibre | |
| | 113 | 90 | 60 | 5.5 | FR60 | Mineral fibre | |
| | 125 | 30 | 30 | 7.5 | FR30 | Mineral fibre | |
| | 125 | 60 | 60 | 6.0 | FR60 | Mineral fibre | |
| | 125 | 90 | 90 | 5.5 | FR90 | Mineral fibre | |
| | 135 | 30 | 30 | 7.5 | FR30 | Mineral fibre | |
| | 135 | 60 | 60 | 6.0 | FR60 | Mineral fibre | |
| | 135 | 90 | 90 | 5.5 | FR90 | Mineral fibre | |
| | 150 | 30 | 30 | 7.5 | FR30 | Mineral fibre | |
| | 150 | 60 | 60 | 6.0 | FR60 | Mineral fibre | |
| | 150 | 120 | 120 | 5.5 | FR120 | Mineral fibre | |
| | 160 | 30 | 30 | 7.5 | FR30 | Mineral fibre | |
| | 160 | 60 | 60 | 6.0 | FR60 | Mineral fibre | |
| | 160 | 120 | 120 | 5.5 | FR120 | Mineral fibre | |

Notes:

- 1) LPCB ref 545a/05 - Wall panels can be installed vertically or horizontally.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

C HILL

Page 5 of 11

Date of Issue 25 September 2006

Issue No. 13

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.