

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 545a

EUROBOND LAMINATES LIMITED

Product Name	Thickness (mm)	Fire resistance Integrity (min)	Insulation (min)	Maximum unsupported span (m)	Grade	Core Material	LPCB Ref. No
Rockspan Lite (wall panel)	60	60	30	3.0	FR30	Mineral fibre	545a/09
	75	60	30	3.0	FR30	Mineral fibre	
	100	30	30	5.5	FR30	Mineral fibre	
	100	60	60	4.5	FR60	Mineral fibre	
	100	90	60	4.0	FR60	Mineral fibre	
	125	30	30	5.5	FR30	Mineral fibre	
	125	60	60	4.5	FR60	Mineral fibre	
	125	90	60	4.0	FR60	Mineral fibre	
	150	30	30	5.5	FR30	Mineral fibre	
	150	60	60	5.5	FR60	Mineral fibre	
	150	120	90	5.0	FR90	Mineral fibre	
	175	30	30	5.5	FR30	Mineral fibre	
	175	60	60	5.5	FR60	Mineral fibre	
	175	120	90	5.0	FR90	Mineral fibre	

Notes:

- 1) LPCB ref 545a/09 - Wall panels can be installed vertically or horizontally.

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 9 of 11

Date of Issue 25 September 2006

Issue No. 13

C HILL

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.