

# Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 545a

## EUROBOND LAMINATES LIMITED

Product Name	Thickness (mm)	Fire resistance Integrity (min)	Insulation (min)	Maximum unsupported span (m)	Grade	Core Material	LPCB Ref. No
Firemaster	150	240	240	7.5	FR240	Mineral fibre	545a/11
Wall Ultima	175	240	240	7.5	FR240	Mineral fibre	
	200	240	240	7.5	FR240	Mineral fibre	

**Notes:**

- 1) LPCB ref 545a/11 - Wall panels can be installed vertically or horizontally.
- 2) LPCB ref 545a/11 - Firemaster Wall Ultima wall panel joints to be stitched on both internal and external faces using 4.7mm diameter x 20mm long self-tapping screws at 300mm centres.

This certificate is valid until withdrawn by LPCB.  
To check the validity and the authenticity of this certificate please visit our website [www.RedBookLive.com](http://www.RedBookLive.com) or contact us.

Signed on behalf of the LPCB

C HILL

Page 11 of 11

Date of Issue 25 September 2006

Issue No. 13

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100  
Fax +44 (0)1923 664603 [www.RedBookLive.com](http://www.RedBookLive.com)

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.